

State Water Resources Control Board

November 3, 2017

(Via email and Certified Mail)
CERTIFIED MAIL
NO. 7015 1520 0001 7928 4239

Ms. Chrystelle Bak
Facilities Planning Specialist
Los Rios Community College District
3753 Bradview Drive
Sacramento, California 95827
bakc@losrios.edu

**SUBJECT: NOTICE OF VIOLATION; UNDERGROUND STORAGE TANK SYSTEMS
LOCATED AT COSUMNES RIVER COLLEGE, 8401 CENTER PARKWAY,
SACRAMENTO**

Dear Mr. Bak:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the USTs at your facility on October 25, 2017, pursuant to authority under Health and Safety Code (H&SC), chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to H&SC, chapter 6.7, and California Code of Regulations (CCR), title 23, chapter 16:

No.	Violation	Tank	Start Date	Stop Date	Regulation
1	Failure to Maintain Tank Information – In CERS, the North and South diesel tanks both state steel primary piping. During the inspection, fiberglass primary piping was observed for both tanks.	North and South Diesel	October 25, 2017	Ongoing	23 CCR 2711(a)
2	Failure to Tag Monitoring Equipment – The waste oil Ronan monitoring panel was not tagged with a certification sticker.	Waste Oil	October 25, 2017	Ongoing	23 CCR 2638(f)
3	Failure to Maintain Designated Operator (DO) Records Onsite – The August 2017 DO inspection report was not onsite at the time of inspection.	All	October 25, 2017	Ongoing	23 CCR 2715(e)

Office of Enforcement | 801 K Street, Suite 2300 | Sacramento, CA 95814 | 916.341.5272

FELICIA MARCUS, CHAIR | EILEEN SOBECK, EXECUTIVE DIRECTOR

You are directed to correct the ongoing violations and submit compliance documentation to the State Water Board and Sacramento County Environmental Management Department within sixty (60) days from the date of this letter. Have your DO make specific notations in the next monthly DO report indicating the ongoing violations has been corrected. The monthly DO report and any associated photos must be submitted as proof of compliance.

Please send all compliance documentation to the following:

State Water Board

Mr. Joseph Lovesee
UST Enforcement Unit
Office of Enforcement
State Water Resources Control Board
801 K Street, Suite 2300
Sacramento, California 95814
joseph.lovesee@waterboards.ca.gov

Local CUPA

Ms. Jennea Monasterio
Environmental Scientist
Sacramento County Environmental
Management Department
10590 Armstrong Avenue
Mather, California 95655
monasterioj@saccounty.net

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tank(s) are liable for a penalty of \$500 to \$5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

If you have any questions, please contact me at (916) 341-5551, or by email at amantha.henkel@waterboards.ca.gov.

Sincerely,



Amantha Henkel
Senior Environmental Scientist
UST Enforcement Unit
Office of Enforcement

cc: *(via email only)*

Ms. Jennea Monasterio
Environmental Specialist
Sacramento County Environmental
Management Department
monasterioj@saccounty.net

Mr. Brion McGinness
Environmental Specialist
Sacramento County Environmental
Management Department
mcginnessb@saccounty.net